

PHP100

100 Foot Photoluminescent LED Charged Exit Sign

illuminated during normal building occupation)

COMMENTS:

Activation requires only 5 foot-candles (54 lux) of unfiltered fluorescent, LED,

metal halide, or mercury vapor lighting for 60 minutes (must be externally

PH100 tested and listed per UL924 requirements for use with LED lighting

PROJECT:

•

DATE:

FEATURES



ORDERING INFORMATION PHP100-1-WH-MTEB

1. SERIES	2. FACE COUNT	3. FRAME COLOR	4. MOUNTING
PHP100		- WH	- MTEB
	1 Single 2 Double	WH White	MTEB Top/End/Back Mount

Non-electrical Fast, easy installation

100.0' viewing distance

25+ year life expectancy Maintenance-free

Suitable for hazardous locations

Universal, field installed chevrons

Approved for damp locations

ACCESSORIES; ORDER SEPARATELY

- WG 2 = Wire guard 14.0" X 10.0" X 4.5"
- WG 3 = Wire guard 14.5" X 6.0" X 10.5"
- WG 10 = Wire guard 13.5" X 12.0" X 16.5"

SPECIFICATIONS

CONSTRUCTION

Durable ABS panel

APPROVALS

- UL 924
- NFPA 101 Life Safety Code
- NFPA 70 NEC
- OSHA

WARRANTY

Isolite offers a 3-year limited warranty. For further details, refer to General Warranty and Obligations in the Isolite manual or on our website.

DIMENSIONS



